



Shelby County Tennessee

Mark H. Luttrell, Jr., Mayor

Questions & Answers

Issued: June 22, 2016

RFP 16-006-83

Structural Repairs and Pavement Replacement Shelby County Fire Station #62

TO ALL PROSPECTIVE BIDDERS:

The following questions were submitted by potential vendors. Our answers are listed in **red** below:

Question:

Q1] What is the required load capabilities of each pier?

Answer to Q1: Piers shall be required to carry a minimum of 42,000 pounds.

Q2] What is the safety factor for each pier?

Answer to Q2: Safety Factor shall be a minimum of 2.0